

**Office of the Director Fire & Emergency Services, J&K  
Jammu/Srinagar**

**TO WHOM IT MAY CONCERN**

The Fire & Life Safety Measures/Guidelines issued in favour of J&K Police Public School, Bemina Bye-Pass Srinagar by this Directorate under No. DFES/FP/9/2022-04/CC-7079422-8466 dated: 19.03.2025 through online portal "Singlewindow.jk.gov.in" is hereby authenticated as genuine. The same has been issued on the pattern adopted in Fire & Emergency Services UT of J&K.

No:- DFES/FP/9/2022-04 (CC-7079422)  
Dated:- 22/03/2025

  
**Director**  
**Fire & Emergency Services, J&K**  
**Jammu/Srinagar**

The Principal,  
J&K Police Public School,  
Bemina Bypass Srinagar.  
No DFES/FP/9/2022-04/CC-7079422-8466  
Sub: - Fire & Life safety measures/ guidelines in favour of "J&K Police Public School" situated at Bemina Bypass Srinagar.

Dated. 19.03.2025.

Refnce: Your online application resubmission dated 15.03.2025 Tracking Id No.F1026-3319909.


The inspection of above said school was got carried out by the Deputy Director F&ES Command Srinagar vide his office letter No:- DDS/F-Prv/2025/1193 dated, 10-03-2025 and found that the school is situated at Bemina Srinagar & is 01 Km away from F&ES Station JVC Bemina, accessible for fire tenders in case of emergency. The detailed report with fire safety precautionary measures are as under:-

1. **BLOCK "A" (Main block):-** Is double storeyed CGI sheet roofed building having two staircases of 1.40 meter wide each. Ground floor is comprised upon principal office, Auditorium, Committee room, Sports room, music room, IT room, Academics room and 11 class rooms. 1<sup>st</sup> floor comprised upon library room, Art room, computer lab, examination cell, staff room, physics laboratory, biology laboratory, chemistry laboratory, mathematics laboratory and 11 class rooms.
2. **BLOCK "B" LPD :-** Is double storeyed CGI sheet roofed having single staircase of 1.40 meter wide. Ground floor is comprised upon 05 class rooms and 1<sup>st</sup> floor comprised upon Headmaster office and 05 class rooms.
3. **BLOCK "C":-** Is single storeyed CGI sheet roofed comprised upon Section officer room, I/C store room, Admission section, Account Section and MT Section.
4. **BLOCK "D" Hostel Building:-** Is triple storeyed CGI sheet roofed having a single staircase of 01 meter wide. Ground floor comprised upon 04 rooms and there are 05 rooms in each 1<sup>st</sup> and 2<sup>nd</sup> floors.
5. **BLOCK "E" Hostel Building:-** Is triple storeyed CGI sheet roofed having a single staircase of 01 meter wide. There are 06 rooms in each floor of the building.
6. **BLOCK "F" Hostel Building:-** Is triple storeyed CGI sheet roofed having a single staircase of 01 meter wide. There are 06 rooms in each floor of the building.
7. **BLOCK "G" Hostel Building:-** Is single storeyed CGI sheet roofed building comprised upon 01 Lunch hall having dimension 40'X30'.
8. **Existing Firefighting facilities:-**
  1. Adequate quantity of fire extinguishers are installed in the school premises.

**9.Recommendations :-**

- I. 01 No. each CO<sub>2</sub> type 4.5 capacity fire extinguisher shall be provided near all the electric switch panel boards, in computer lab & in IT section, 01 No. each ABC type 06 kg capacity fire extinguishers shall be provided in chemistry, physics and biology laboratories, 01 No water type 09 liters capacity fire extinguishers shall be provided at each floor of all the (07) buildings, in addition to already existing fire extinguisher.
- II. Hose Reel as per BIS specifications connected with terrace tank of 10,000 Ltrs. Capacity each shall be provided in all the double/ triple storeyed school buildings. The Hose Reel shall be kept at such a place where from every nook and corner of each floor of all the school buildings are covered easily at the time of any emergency. A Fire pump of desired capacity shall be installed near terrace water storage with dual electric supply for feeding the Hose Reel.
- III. Manually Fire alarm System shall be provided in Block "A" and in all triple storeyed Hostel buildings.
- IV. An additional staircase of 1.5 m wide well away from the existing exit shall be provided in the LPD Block/ Hostel blocks for the safe & hassle free evacuation of inmates during any emergency.
- V. Wooden components of the material like wood etc. need to be replaced by noncombustible material or alternatively fire retardant paint of two hours rating shall be given for wooden components.
- VI. The exits shall allow free access for fire tenders in case of emergency.
- VII. Examination/ computer hall & class rooms having capacity of more than 45 students shall have at least two exits.
- VIII. Space under the escape routes at ground level if used as electric control panel shall not be allowed.
- IX. Attic portion of the buildings shall not be used for any kind of storage. Grill fitted in the windows essentially in ground floor shall be removed. Fire/Evacuation drill shall be conducted regularly.
- X. Employees of the school shall be trained for maintenance & use of fire fighting equipments.
- XI. No Hazardous material shall be kept inside of the school premises (especially LPG cylinder, Petrol, Diesel etc.) Any deviation found in this regard, these fire & life safety measures/guidelines issued will be treated automatically withdrawn/cancelled.

- XII. The Management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
- XIII. At present school is functional in 07 Blocks. As such no addition/ alteration should be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, these fire safety measures/guidelines will be treated automatically withdrawn/ cancelled.
- XIV. The department can make a surprise visit to your college at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, these fire safety measures/guidelines issued shall be treated automatically withdrawn/cancelled.
- XV. These fire safety measures/guidelines shall be subject to outcome of any dispute/investigation enquiry/trial if any pending before any court of Law/investigation agency. These fire safety measures/guidelines shall not confirm any title upon the person/company in whose favour it is issued.
- XVI. These fire safety measures/guidelines issued in respect of the institution with validity of six months for adoption of all fire safety measures/guidelines mentioned above.
- XVII. The final fire safety certificate will be issued subject to fulfillment of all the fire safety measures/guidelines in letter and spirit. However, before granting permission/recognition/extension or renewal thereof, the concerned authority shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 & SRO-292 of 2018 issued by Education Department with regard to physical facilities & also ensure the fire safety measures/guidelines given to the proprietor by this department are fully complied with.

  
Director, 19/03/2025  
Fire & Emergency Services J&K,  
Srinagar/Jammu