

Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar

Tel-0194-2455061
Email: info.fesjk@jk.gov.in

The Principal,
J&K Police Public School,
Bemina Srinagar.
No: DFES/FP/9/2022-04/CC-7079422-

Dated 26.12.2022.

Sub: - Provisional Fire safety Certificate.
Ref: - Your online Tracking Id No. FI. 238014.

The Inspection of above said school was got carried out by the inspecting officer of this department and found that the management has installed 06 units of ABC type 06 kg & 05 units of water type 09 liter first aid fire extinguishers in their school premises. Moreover the site is 01 km away from Fire & Emergency JVC (Weir) and is accessible for fire appliance. Since the school is already comprising upon 7 structures, three triple storeyed, Two double storeyed and two single storeyed buildings, as such the management can proceed ahead for operation provisionally subject to strictly adopt the following fire safety measures/guidelines in letter and spirit forthwith for the safety of students studying there: -

- 01 no. each of CO₂ type fire extinguisher 4.5 kg capacity shall be provided near main electric Switch board panels of all the buildings and 02 no. water type 09 liters capacity / 02 no. ABC type 06 kg capacity fire extinguisher shall be provided in each floor of all the buildings, in addition to already existing fire extinguishers.
- Hose Reel as per BIS specifications connected with terrace tank of 5000 Ltrs. Capacity shall be provided in the all the double & triple storeyed school buildings. The Hose Reel shall be kept at such a place where from every nook and corner of each floor of school building are covered easily at the time of any emergency. A Fire pump of desired capacity should be installed near terrace water storage with dual electric supply for feeding the Hose Reel Hose.
- Wooden components of the structures especially in attic portion shall be given fire retardant treatment of at least two hours rating.
- All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency. The corridor of the building shall not be used for any kind of storage.
- No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol, Diesel and Central Heating System etc.) Any deviation found in this regard, this provisional clearance issued will be treated automatically withdrawn/cancelled.
- The Management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
- Class/Halls have a capacity of more than 45 students shall have two exits. Fire/Evacuation drill should be conducted regularly. Employees of the school shall be trained for maintenance & use of Fire Fighting facilities.
- The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, this provisional clearance issued shall be treated automatically withdrawn/cancelled.
- At present school is functioning in 7 structures, three triple storeyed, two double storeyed and two single storeyed all GCI sheet roofed pacca. As such no addition/ alteration should be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, this provisional clearance will be treated automatically withdrawn/cancelled.
- An alternate exit 1.5 meter wide, well away from the existing shall be provided in all the triple storeyed buildings.
- The already existing exists of 3.5 feet & 03 feet width needs to be replaced by minimum 1.5 meter wide exit.
- The exit signs shall be marked in all the buildings to lead the occupants to the place of safety.
- The extinguisher installed in buses shall be refilled.
- This provisional clearance shall be subject to outcome of any dispute/investigation enquiry/trial if any pending before any court of Law/investigation agency. This provisional clearance shall not confirm any title upon the person/company in whose favour it is issued.
- The validity of this provisional clearance shall remain in force for one year and same needs to be renewed after checking of fire fighting system installed in the school building (i.e. existing as well as proposed). However, before granting permission/recognition/extension or renewal thereof, the competent authority shall satisfy himself in terms of conditions laid down in SRO-123 of 2010, issued by Education Department with regard to Physical facilities.

Principal
JK Police Public School
Bemina Srinagar

Director, Director,
Fire & Emergency Services,
J&K, Srinagar